


SYSTEMS INTEGRATION MADE EASY WITH A DIGITAL TWIN

CLAIRE PENNY

31st January 2023




SYSTEM INTEGRATORS

Gartner Glossary

[Gartner Glossary](#) > [Information Technology Glossary](#) > [S](#) > [SI \(System Integrator\)](#)

SI (System Integrator)


An enterprise that specializes in implementing, planning, coordinating, scheduling, testing, improving and sometimes maintaining a computing operation. SIs try to bring order to disparate suppliers.




TYPICAL BUILDING SYSTEMS




Civil




Electrical




Energy



Mechanical



Plumbing



Structural




Technology


TYPICAL BUILDING SYSTEMS




Civil




Electrical




Energy



Mechanical




Plumbing



Structural



Technology



S S Stakeholders



S S Software



U U Users & Use cases

LANGUAGE BARRIER

Monolithic legacy systems

I see data differently to you...

Scalability

Data classification



Future proofing

Integration


Business need

Data silo's

Ontologies

CLASSIFY THE DATA

MAKE IT MACHINE READABLE




Object Model Classification

- Space
- Product
- Discipline
- System
- Etc.



Goose vs Duck


- Make **everyone** classify a duck as a duck and not a goose
- Rules based automation to assist with classification is needed



Downstream Uses

- Quantification
- Cost Estimation
- Scheduling
- Asset Management
- Maintenance

SI'S ARE IN A UNIQUE POSITION





By using a composable Digital Twin platform you can:

- bring all the **disparate systems** and technologies together into **one place**.
- integrate 3rd party building technologies to **persist, expose, analyse and visualise data**
- provide a **360 degree insight** of building performance, driving down CAPEX and OPEX.

JOURNEY TO A DIGITAL TWIN


Defining use cases, and the requirements for data & information to deliver them, is the **key to success**. **1**

BIM Data Management ensures 3D models are machine readable, and usable for data workflows. **2**



At project handover, an Asset Twin / Performance Twin integrates all information into an associative information model. **3**

At this phase the data is organised and ready for operationalisation. **4**





Carbon

- Net zero carbon manufacturing by 2030
- 50% reduction in product CO2e intensity from our primary supply partners by 2030
- Zero emission company funded cars by 2025



EPD Documents

Traceability

Fire Testing

Electrical Consumption

1,272,370 kWh

Last 12 Months

Solar Generation

8,624 kWh

Last 12 Months

Avoided Carbon

311,731 kg

Last 12 Months


Rainwater Harvesting

461,952 l

Last 12 Months

Role based use interfaces, to provide just the right information that matters to each stakeholder. Adds value to Operations & Maintenance, Sustainability agenda at an asset / portfolio level.

Valuable information for certification, such as WELL



The Asset Twin is a "Digital Manual" of the facility. An information model that associates equipment, systems and spaces to relevant data and documents. Accessed online with a web browser, on the desk or the field on tablets.

Filter by:

Choose filters

1490 Assets

- 01-FIRST FLOOR 467
- 02-SECOND FLOOR 43
- 03-THIRD FLOOR 44
- 04-FOURTH FLOOR 42
- 05-FIFTH FLOOR 576
- B-BASEMENT1 84
- GF-GROUND FLOOR 166
- ROOF 68
- PACKAGE PLANT ROOM - 298 38
 - Air Seperator 2
 - Boiler 4
 - Chilled Water Pump 8
 - Dosing Pot 2
 - Expansion Tank 4
 - Hot Water Pump 12
 - Pressurization Equipment 2
 - Shunt Pump 4
- ROOF - 212 29
- SHAFT - 252 1



Reset View Shading Navigation Measurement Settings

Search icons

Chilled Water Pump CWH P-R-09 Common Plant Room - 212


Asset Test Data ^

| | Units | 18/02/2020 |
|-----------------------------------|-------|--------------|
| Record Motor Running Current | | 9.6/9.7/9.7a |
| Record Overload Range & Set Point | A | 11 |
| Record Supply Voltage & Set Point | | 411/410/411v |
| Speed | | |

Files ^

| Name | Description | Document Type |
|---|--|----------------------|
| CH Circuit 3 FCU West.pdf | Pumps P-R-05 & 06 - CH Circuit 3 FCU West - Technical Data | Technical Data Sheet |
| CHW Circuit 1 AHU.pdf | Pumps P-R-01 & 02 - CHW Circuit 1 AHU - Technical Data | Technical Data Sheet |

Various data sets relating to equipment such as specifications, warranty, testing data is directly linked to the equipment with the O&M documents



- Reset
- View
- Shading
- Navigation
- Measurement
- Settings



F.06 - First Floor | Fan Coil Unit - AC | ID8316

Asset Properties


Realtime Readings

Refreshed less than a minute ago

| Point Name | Point Reading | Point Status |
|--------------------|---------------|--------------|
| AlarmSignal | normal | ok |
| ErrorCode | Normal | ok |
| FanSpeedSetup | Low | ok |
| FanSpeedState | Mid2 | ok |
| OnOffSetup | on | ok |
| OnOffState | on | ok |
| OperationModeSetup | Fan | ok |
| OperationModeState | Auto | ok |
| RoomTemp | 21.70 °C | ok |
| SetTemp | 20.00 °C | ok |

Files

Real time performance data from the BMS system, can be visualised in the context of selected equipment.





HEATING



LPH HEADER TEMP

Flow Temperature 68.00°C
Return Temperature 63.36°C

BOILER ENABLED

Boiler 1
Boiler 2
Boiler 3
Boiler 4

LPHW HEADER PUMPS

EAST FCU
Flow Temperature 61.9°C
Flow Rate 0 l/h

WEST FCU
Flow Temperature 63.5°C
Flow Rate 0 l/h

AHU
Flow Temperature 51°C
Flow Rate 0 l/h

LANDLORD FCU
Flow Temperature 51.9°C
Flow Rate 0 l/h

COOLING



CHILLER / 1

Flow Temperature 9.32°C
Return Temperature 9.74°C

CHILLER / 2

Flow Temperature 9.87°C
Return Temperature 10.02°C

CHW HEADER PUMPS

EAST FCU
Return Temperature 13.1°C
Flow Rate 0 l/h

WEST FCU
Return Temperature 13.2°C
Flow Rate 0 l/h

AHU
Return Temperature 25.8°C
Flow Rate 0 l/h

LANDLORD FCU
Return Temperature 20.4°C
Flow Rate 0 l/h

DOMESTIC HOT WATER



TANK / 1

Tank Temperature 51.61°C
CT Switch - Return Pumps

TANK / 2

Tank Temperature 51.98°C
CT Switch - Return Pumps

PRIMARY VENTILATION



WEST AHU / 1


Supply Air Temperature 17.52°C
Supply Air Volume 7.21m³/h

EAST AHU / 2


Supply Air Temperature 16.63°C
Supply Air Volume 6.75m³/h

Energy Analytics | Consumption by Load Type


Consumption by Load Type




Consumption by Load Type - Monthly Trend




Consumption by Load Type - Daily Trend




Consumption by Load Type - Hourly Average




SI MADE EASY WITH A DIGITAL TWIN PLATFORM




Faster time to value




Cheaper to deliver desired out comes



Streamline integration and remove friction



Repeatable and scalable





THANK YOU

QUESTIONS?

Claire Penny

Director of Global Partnerships

claire.penny@invicara.com