

**Houston Fire Department
Vehicle Safety Inspection Checklist
For Indoor Display of Liquid or Gas-Fueled Motorized Vehicles**

Date of Inspection: _____ Venue: _____

Name of Event: _____

Booth Number _____ Exhibitor Name _____

Motorized Vehicle Type:

Car Truck Boat Personal Watercraft

Motor-Driven Cycle Aircraft

Other (specify): _____

In order to comply with the City of Houston Fire Code Regulations, the following requirements must be adhered to:

- Fuel in fuel tanks shall not exceed one-fourth (1/4) capacity or 5 gallons, whichever is least. An accurate means of measuring the fuel amount shall be provided. (Pre-requisite to entry into the building.)
- Batteries must be disconnected.
- Fuel tanks and fill openings shall be closed and sealed to prevent tampering.
- Propane cylinders shall be new and unused unless prior written approval has been given by the Fire Marshal. The Vendor or his representative will disconnect piping from the cylinder. Valves will be opened to verify the cylinder is void of propane gas. Any tools required shall be provided by the vendor.

Approved for display.

Rejected for display.

Reason(s) for rejection: _____

Fire Inspector (Print): _____

Signature of Fire Inspector: _____